

# THE CITY OF REDMOND FIRE DEPARTMENT - PREVENTION DIVISION

# Uniform Fire Code Administrative Ruling / Interpretation



Code Section: UFC 1006.2.2 and 1006.2.7 Code Edition: 1997

Date: September 12, 2000

### Statement of Need:

Two changes in commercial food preparation techniques have had a significant impact on fire protection in recent years:

- <u>Vegetable oils</u> burn at a higher temperature (685 plus deg. F) than animal fats (550-600 deg. F).
- <u>Energy efficient cooking appliances</u> are now used extensively in restaurants. Highly insulated fryers keep cooking oils and metal appliances hot longer.

These two changes have created conditions that create fires that are <u>more difficult to extinguish</u> and <u>prone to re-ignite</u>. There are documented fires in cooking equipment that were not controlled by the existing pre U.L. 300 extinguishing systems. <u>Extinguishment was affected only after application of 1-3/4" hand lines</u>.

On November 21, 1994, Underwriters Laboratories adopted a new standard, *UL 300-Fire Testing of Fire Extinguishing Systems for Protection of Restaurant Cooking Areas,* which test for these specific hazards. The U.L 300 standard provides for much greater cooling of the <u>cooking surfaces</u> (requires up to five times additional agent for wet chemical systems). Note: <u>There are currently no dry chemical agent extinguishing systems that meet the U.L. 300 standard due to the susceptibility for re-ignition of the fire.</u>

## Ruling/Interpretation:

#### UFC 1006.2.2, "Protection of Commercial Cooking Operations - Type of system":

- U.L. 300 compliant systems shall be required for all new installations of fire extinguishing systems that protect cooking equipment that have the potential to release grease laden vapors.
- Existing extinguishing systems protecting cooking equipment that do not comply with U.L. 300 shall be brought into compliance with that standard within 6 months of written notification by Fire Prevention personnel.

# **UFC 1006.2.7, "Protection of Commercial Cooking Operations – Portable fire extinguishers":**

New and existing cooking appliances using combustible cooking media (vegetable or animal oils and fats) shall have a "**K-type**" portable fire extinguisher installed within 30 feet in lieu of a 40-B:C dry chemical-type in accordance with NFPA 10 – 1998, "Standard for Portable Fire Extinguishers", Section 3-7, "Fire Extinguisher Size and Placement for Class K Fires".

Robert Lovett
Fire Marshal